

# Sulfur Hexafluoride and the Electric Power Industry

**Key Words:** Circuit breakers, gas-insulated transformers, gas-insulated transmission lines, greenhouse effect, high voltage insulation

by

L. G. CHRISTOPHOROU, J. K. OLTHOFF, AND  
R. J. VAN BRUNT

National Institute of Standards and Technology

*Because of the many and increasing commercial uses of SF<sub>6</sub>, there has been an increased demand for it. In turn, this has resulted in increased concentration of SF<sub>6</sub> in the atmosphere.*

## INTRODUCTION

Sulfur hexafluoride (SF<sub>6</sub>) is a man-made gas that became commercially available in 1947 [1]. It is one of the most extensively and comprehensively studied molecular gases to date largely because of its many commercial and research applications. (Besides the use of SF<sub>6</sub> by the electric power industry, other uses include: semiconductor processing, blanket gas for magnesium refining, reactive gas in aluminum recycling to reduce porosity, thermal and sound insulation, airplane tires, spare tires, "air sole" shoes, scuba diving, voice communication, leak checking, atmospheric trace gas studies, ball inflation, torpedo propeller quieting, wind supersonic channels, and insulation for AWACS radar domes). Its basic physical and chemical properties, behavior in various types of gas discharges, and uses by the electric power industry have been broadly investigated (see, for example, [2-7]). In its normal state, it is chemically inert, nontoxic, nonflammable, nonexplosive, and thermally stable (it does not decompose in the gas phase at temperatures  $T < 500^\circ\text{C}$ ). Because of its relative inertness and its nontoxic characteristics, it is generally assumed to be an environmen-

tally safe and acceptable material in the sense that it does not interact unfavorably with the biomass.

Sulfur hexafluoride exhibits many properties that make it suitable for equipment utilized in the transmission and distribution of electric power. SF<sub>6</sub> is a strong electronegative (electron attaching) gas both at room temperature and at temperatures well above ambient, which principally accounts for its relatively high dielectric strength and good arc-interruption properties. The breakdown voltage of SF<sub>6</sub> is nearly three times higher than air at atmospheric pressure [6]. Furthermore, it has good heat transfer properties and it readily reforms itself when dissociated under high gas-pressure conditions in an electrical discharge or an arc (that is, it has a fast recovery and it is self-healing). Most of its stable decomposition byproducts do not significantly degrade its dielectric strength and are removable by filtering. It produces no polymerization, carbon, or other conductive deposits during arcing, and it is chemically compatible with most solid insulating and conducting materials used in electrical equipment at temperatures up to  $200^\circ\text{C}$ .

Besides its good insulating and heat transfer properties, SF<sub>6</sub> when contained has a relatively high pressure at room temperature. The pressure required to liquefy SF<sub>6</sub> at  $21^\circ\text{C}$  is about 2,100 kPa [5, 8]; its boiling point is reasonably low,  $-63.8^\circ\text{C}$ , and allows pressures of 400 kPa to 600 kPa to be employed in SF<sub>6</sub>-insulated equipment). It is easily liquefied under pressure at room temperature, allowing for compact storage in metal cylinders. It presents no handling problems, is readily available, and up until recently has been reliably available and reasonably inexpensive. (From 1960 to 1994 the price of SF<sub>6</sub> in quantity purchases remained basically constant at about \$3 per pound [one pound = 0.4536 kilogram]. The current prices of SF<sub>6</sub> for quantity purchases is over \$30 per pound). The electrical industry has become familiar and experienced with using SF<sub>6</sub> in electrical equipment.

However, SF<sub>6</sub> has some undesirable properties: it forms highly toxic and corrosive compounds when subjected to electrical discharges; nonpolar contaminants, e.g., air, CF<sub>4</sub>, are not easily removed from it; its breakdown voltage is sen-



sitive to water vapor, conducting particles, and conductor surface roughness; and it exhibits nonideal gas behavior at the lowest temperatures that can be encountered in the environment, i.e., in cold climatic conditions (about  $-50^{\circ}\text{C}$ ),  $\text{SF}_6$  becomes partially liquefied. Sulfur hexafluoride is also an efficient infrared (IR) absorber, and due to its chemical inertness is not rapidly removed from the earth's atmosphere. Both of these latter properties make  $\text{SF}_6$  a potent greenhouse gas, although due to its chemical inertness (and the absence of chlorine atoms in the  $\text{SF}_6$  molecule) it is benign with regard to stratospheric ozone depletion.

## PRINCIPAL USES OF $\text{SF}_6$ BY THE ELECTRIC POWER INDUSTRY

Sulfur hexafluoride is the electric power industry's preferred gas for electrical insulation and, especially, for arc quenching/current interruption equipment used in the transmission and distribution of electrical energy. Generally, there are four major types of electrical equipment that use  $\text{SF}_6$  for insulation and/or interruption purposes: gas-insulated circuit breakers, gas-insulated transmission lines, gas-insulated transformers, and gas-insulated substations. It is estimated [9-11] that for these applications the electric power industry uses about 80% of the  $\text{SF}_6$  produced worldwide, with circuit breaker applications accounting for most of this amount. Gas-insulated equipment is now a major component of power transmission and distribution systems all over the world, and it employs  $\text{SF}_6$  almost exclusively. It offers significant savings in land use, is aesthetically acceptable, has relatively low radio and audible noise emissions, and enables substations to be installed in cities very close to the loads.

Depending on the particular function of the gas-insulated equipment, the gas properties that are the most significant vary. For *circuit breakers* the excellent thermal conductivity and high dielectric strength of  $\text{SF}_6$ , along with its fast thermal and dielectric recovery (short time constant for increase in resistivity), are the main reasons for its high interruption capability. These properties enable the gas to make a rapid transition between the conducting (arc plasma) and the dielectric state of the arc, and to withstand the rise of the recovery voltage.  $\text{SF}_6$ -based circuit breakers are superior in their performance to alternative systems such as high-pressure air blast or vacuum circuit breakers. For *gas-insulated transformers* the cooling ability, compatibility with solid materials, and partial discharge characteristics of  $\text{SF}_6$ —added to its beneficial dielectric characteristics—make it a desirable medium for use in this type of electrical equipment. The use of  $\text{SF}_6$  insulation has distinct advantages over oil insulation, including the avoidance of breakdown due to charge accumulation on insulators, no fire safety problems, high reliability, flexible layout, little maintenance, protected insulation, long service life, lower noise, better handling, and lighter equipment. For *gas-insulated transmission lines* the dielectric strength of the gaseous medium under industrial conditions is of paramount importance, especially the




Fig. 1: Average  $\text{SF}_6$  concentration (pptv = parts in  $10^{12}$  by volume) between 12 km and 18 km altitude as a function of time [15]. ○ University of Denver balloon-borne infrared measurements at  $32^{\circ}\text{N}$  latitude; ● Spacelab 3 ATMOS data at  $31^{\circ}\text{N}$  latitude; ■ Average of ATMOS ATLAS 1 data at  $28^{\circ}\text{S}$  and  $54^{\circ}\text{S}$  [15].

behavior of the gaseous dielectric under metallic particle contamination, switching and lightning impulses, and fast transient electrical stresses. The gas must also have a high efficiency for transfer of heat from the conductor to the enclosure and be stable for long periods of time (say, 40 years).  $\text{SF}_6$ -insulated transmission lines offer distinct advantages: cost effectiveness, high-carrying capacity, low losses, availability at all voltage ratings, no fire risk, reliability, a compact alternative to overhead high-voltage transmission lines in congested areas, and avoidance of public concerns with high-voltage overhead transmission lines.

## CONCENTRATIONS OF $\text{SF}_6$ IN THE ENVIRONMENT

Because of the many and increasing commercial uses of  $\text{SF}_6$ , there has been an increased demand for it. The estimated world production of  $\text{SF}_6$  has steadily increased since the 1970s to  $\sim 7,000$  metric tons per year in 1993 [9-13]. In turn, this has resulted in increased concentration of  $\text{SF}_6$  in the atmosphere [11-17]. As seen in Fig. 1, recent measurements [15, 17] have shown that the amount of  $\text{SF}_6$  in the atmosphere has been increasing at a rate of  $\sim 8.7\%/yr$ , from barely measurable quantities a decade ago to current levels of  $\sim 3.2$  pptv ( $\sim 3.2$  parts in  $10^{12}$  by volume). The atmospheric concentration of  $\text{SF}_6$  could reach 10 pptv by the year 2010 depending upon the assumptions of release rates (see [11, 14, 15, 17] and Fig. 2). In many industrial applications  $\text{SF}_6$  is not recoverable, and the releases of  $\text{SF}_6$  into the environment by the electric power industry come from normal equipment leakage, maintenance, reclaiming, handling, testing, etc. Without disposal methods that actually destroy  $\text{SF}_6$ ,



it can be expected that all of the  $\text{SF}_6$  that has ever been or will ever be produced will eventually enter the atmosphere (within the next few centuries). This is so even if the present  $\text{SF}_6$  leak rate from enclosed power-system equipment is only 1% per year or is improved to 0.5 % per year. This release of  $\text{SF}_6$  into the environment cannot be reduced significantly since there are no currently accepted economically feasible methods for controlling or destroying  $\text{SF}_6$  as it leaks from enclosures. It has been suggested that impure used  $\text{SF}_6$  in storage containers can be destroyed by thermal decomposition in industrial waste treatment furnaces at elevated temperatures ( $T > 1,100^\circ\text{C}$ ) [9].

However, decreasing the rate of  $\text{SF}_6$  leakage and increasing the level of recycling are high priorities since they will both curtail production needs of  $\text{SF}_6$  and thus will reduce the quantities of  $\text{SF}_6$  that are eventually released into the environment. Indeed, efforts have recently been undertaken by the electric power industry to better monitor the gas pressure in  $\text{SF}_6$ -insulated equipment and the amount of  $\text{SF}_6$  released into the environment [9-11]. These efforts include improved methods to quantify and stop leakages, better pumping and storage procedures, setting of standards for recycling, manufacturing tighter and more compact equipment, development of sealed-for-life electrical apparatus, gradual replacement of older equipment which normally leaks at higher rates, and implementation of a sound overall policy of using, handling, and tracing  $\text{SF}_6$ . (We acknowledge private discussions on these issues with P. Bolin of Mitsubishi Electric Power Products, Inc. [USA], J. Brunke of Bonneville Power [USA], H. Morrison of Ontario Hydro [Canada], M.F. Frechette of IREQ [Canada], L. Niemeyer of ABB Research Corp. [Switzerland], and A. Diessner of Siemens AG [Germany]). These efforts are partially motivated by the prospect of regulation and the possibility of imposition of controls on the use and transport of  $\text{SF}_6$  [11, 13, 20]. The overall concern is motivated by virtually one and one reason only:  *$\text{SF}_6$  is a potent greenhouse gas.*

## **$\text{SF}_6$ IS A POTENT GREENHOUSE GAS**

Greenhouse gases are atmospheric gases that absorb a portion of the infrared radiation emitted by the earth and return it to earth by emitting it back. Potent greenhouse gases have strong infrared absorption in the wavelength range from  $\sim 7\ \mu\text{m}$  to  $13\ \mu\text{m}$  and occur naturally in the environment (e.g.,  $\text{H}_2\text{O}$ ,  $\text{CO}_2$ ,  $\text{CH}_4$ ,  $\text{N}_2\text{O}$ ) or are man-made gases that are released into the environment, e.g., fully fluorinated compounds (FFC); combustion products such as  $\text{CO}_2$ , nitrogen, and sulfur oxides;  $\text{SF}_6$ . The effective trapping of infrared radiation by the greenhouse gases and its re-radiation back to earth results in an increase in the average temperature of the earth's atmosphere. The effect is known as the "greenhouse effect." The man-produced contribution to the greenhouse effect shifts the balance between incoming and outgoing radiation at the top of the earth's troposphere toward the former, causing "global warming."

Sulphur hexafluoride is an efficient absorber of infrared radiation, particularly at wavelengths near  $10.5\ \mu\text{m}$  [18]. Additionally, unlike most other naturally occurring greenhouse gases (e.g.,  $\text{CO}_2$ ,  $\text{CH}_4$ ),  $\text{SF}_6$  is largely immune to chemical and photolytic degradation and therefore its contribution to global warming is expected to be cumulative and virtually permanent. Although the determination of the lifetime of  $\text{SF}_6$  in the environment (the time taken for a given quantity of  $\text{SF}_6$  released into the atmosphere to be reduced via natural processes to  $\sim 37\%$  of the original quantity) is highly uncertain because of the lack of knowledge concerning the predominant mechanism(s) of its destruction, it is very long; estimates range from 800 years to 3,200 years [11, 13, 19-22]. The strong infrared absorption of  $\text{SF}_6$  and its long lifetime in the environment are the reasons for its extremely high global warming potential, which for a 100-year horizon is estimated to be  $\sim 25,000$  times greater than that of  $\text{CO}_2$ ,




Fig. 2: Atmospheric  $\text{SF}_6$  concentration (pptv = parts in  $10^{12}$  by volume) as a function of time. The solid curve represents the estimated cumulative total  $\text{SF}_6$  from gas-insulated equipment in the past, the open points are measured atmospheric trace concentrations, the solid point labeled "installed" is the estimated concentration assuming that all  $\text{SF}_6$  enclosed in electrical equipment throughout the world in 1990 has been released into the atmosphere, and the broken lines are projected increase under various assumptions [12, 14].



the predominant contributor to the greenhouse effect [19]. The concern about the presence of SF<sub>6</sub> in the environment derives exclusively from this very high value of its potency as a greenhouse gas.

While the potency of SF<sub>6</sub> as a greenhouse gas is extremely high, the amount of SF<sub>6</sub> in the atmosphere should, in the near term, be too small to have significant environmental consequences. Estimates of the relative contribution of SF<sub>6</sub> to non-natural global warming—using 1993 estimated SF<sub>6</sub> concentration levels—range from 0.01% [11] to 0.07% [9, 10]; in 100 years this value could become as high as 0.2% [9]. Government and environmental protection agencies, electrical, chemical, and other industries using or interested in the use of SF<sub>6</sub> [6, 11-13, 20] have expressed concerns over the possible long-term environmental impact of SF<sub>6</sub>, and the electric power industry is responding in a multiplicity of ways to better control SF<sub>6</sub> than in the past and to reduce its releases into the environment [9-11]. Because SF<sub>6</sub> is already widely used, there are obvious economic implications about any attempts to regulate or control its production, use, and eventual disposal.

## SF<sub>6</sub> SUBSTITUTES

Gaseous insulation must be environmentally acceptable, now and in the future. Therefore, the best response to the concerns over the possible impact of SF<sub>6</sub> on global warming is to prevent the release of SF<sub>6</sub> into the environment. Clearly the most effective way to do this is not to use SF<sub>6</sub> at all. While such a proposition might be environmentally attractive, it is presently difficult to envision the near term elimination of the use of SF<sub>6</sub> in view of the demonstrated industrial and societal value. However, it stresses the need for a search for alternative gaseous insulation and perhaps also the need for alternative high-voltage insulation technologies. SF<sub>6</sub>-substitute gaseous dielectrics are more difficult to find than it seems on the surface because of the many basic and practical requirements that a gas must satisfy and the many studies and tests that must be performed. For example, the gas must have a high dielectric strength, which requires the gas to be electronegative; however, strongly electronegative gases are usually toxic, chemically reactive, environmentally damaging, have low vapor pressure, and their decomposition in the various types of gas discharges is extensive and unknown. Nonelectronegative gases that are benign and environmentally ideal, such as N<sub>2</sub>, normally have low dielectric strengths. For example, N<sub>2</sub> has a dielectric strength about three times lower than SF<sub>6</sub> and lacks the fundamental requirements for use by itself in circuit breakers. Nonetheless, such environmentally friendly gases might be used by themselves at higher pressures, or at comparatively lower pressures, as the main component in mixtures with electronegative gases, including SF<sub>6</sub>, at partial concentrations of a few per cent. Suggestions have been made repeatedly over the last two decades to use high-pressure N<sub>2</sub> and mixtures of N<sub>2</sub> with SF<sub>6</sub> for insulation, arc quenching, and current interruption [2-4, 6], and more recently, high-

pressure nitrogen is seriously being considered for gas-insulated transmission [6, 23]. Mixtures of N<sub>2</sub> / SF<sub>6</sub> have been and are being used in circuit breakers under severe weather conditions (T < -40° C) where SF<sub>6</sub> used under pressure in circuit breakers may liquefy and thus lose part of its current interruption properties. It was found that for such uses the SF<sub>6</sub>/N<sub>2</sub> mixtures with 50% SF<sub>6</sub> are efficient arc interrupting media [24, 25]. Besides SF<sub>6</sub>/N<sub>2</sub>, other mixtures in use include SF<sub>6</sub>/CF<sub>4</sub> and SF<sub>6</sub>/He [3, 25, 26].

The search for SF<sub>6</sub> substitutes traces back many years. It was especially intense in the 1970s and 1980s, when gases "superior" to SF<sub>6</sub> were sought. A number of studies conducted mainly during this time period produced a large body of valuable information (see, for example, [2, 3]) that needs to be revisited and reassessed not so much for finding "better" gaseous dielectrics than SF<sub>6</sub> but rather from the point of view of finding gases/mixtures that are environmentally acceptable and comparable in dielectric properties and performance to SF<sub>6</sub>. A rekindled interest in "new" gaseous insulators may also direct itself to finding gases/mixtures that are not necessarily universally optimum for each and every high-voltage insulation need but that can be optimized for a particular application.

A program on substitutes needs to address comprehensively the issues involved and evaluate possible substitutes within the framework of the total environment. Besides the obvious requirements of high gas pressure, nontoxicity, nonflammability, availability, and cost, there should be basic, applied, and industrial testing to assess the thermal and electrical properties of the gaseous dielectric. Its performance under various test voltages (dc, ac, impulse, transients), field configurations, and particle contamination must be assessed, as well as studies conducted of gas decomposition under prolonged electrical stress, corona, breakdown, and arc, ageing, and influence of spacer and other materials. Gas mixtures in particular need to be looked at anew, and efforts need to be made to address industry's concerns with regard to difficulties in handling, mixing, maintaining constant composition, and reclamation of the mixture's constituents.

## CONCLUSIONS

The use of gas-insulated electrical equipment has a demonstrated value for society. The problems relating to SF<sub>6</sub> are not without solution and can lead to new opportunities. To this end, besides the current efforts to curtail the releases of SF<sub>6</sub> into the environment, a comprehensive and focused program is needed to develop alternative gaseous insulators and alternative high-voltage technologies.

## ACKNOWLEDGMENTS

We wish to thank Dr. Alan H. Cookson and Dr. David S. Green of The National Institute of Standards and Technology for valuable comments.





LOUCAS G. CHRISTOPHOROU received his B.Sc. degree in physics from the University of Athens, Greece, and his Ph.D. and D.Sc. degrees from the University of Manchester, England. From 1963 to 1994 he was at Oak Ridge National Laboratory and at the University of Tennessee. At Oak Ridge, he served as head of the Atomic, Molecular, and High Voltage Physics Group, and he was appointed corporate fellow in 1981 and senior corporate fellow in 1991. At the University of Tennessee he has been a Ford Foundation professor of physics since 1969. He is currently at the National Institute of Standards and Technology and The University of Tennessee. He conducted extensive and broad research in atomic and molecular physics, radiation physics and chemistry, chemical physics and photophysics, electron and ion physics, and materials for radiation detector, pulsed power, gaseous dielectrics, and plasma processing. He can be reached at the U.S. Dept. of Commerce, NIST, Bldg. 220, Room B344, Gaithersburg, MD 20899-0001, or at the Department of Physics, The University of Tennessee, Knoxville, TN 37996-1200.



JAMES K. OLTHOFF received his B.A. from Calvin College in physics and mathematics, and his Ph.D. in physics from the University of Maryland in 1985. He then became a post-doctoral fellow at The Johns Hopkins School of Medicine. Since 1987 he has been a researcher at the National Institute of Standards and Technology, and he is presently the leader of the Electrical

Systems Group of the Electricity Division. He has performed research in the areas of atomic and molecular physics, with an emphasis on electron molecule interactions, plasma processing, and gaseous dielectrics.



RICHARD VAN BRUNT received his B.Sc. in physics from the University of Florida in 1961 and his Ph.D. in physics from the University of Colorado-Joint Institute for Laboratory Astrophysics in 1969. He has been a researcher at the National Institute of Standards and Technology since 1978 and is presently a NIST fellow in the Electrical Systems Group of the Electricity Division. He is an IEEE fellow and was the IEEE Whitehead Memorial Lecturer in 1994. He has conducted extensive research in atomic and molecular physics, with recent emphasis on gaseous dielectrics, plasma processing, and partial discharge detection.

## REFERENCES

1. G. Camilli, "Gas-insulated Power Transformers," *Proc. IEE*, Vol. 107 A, pp. 375-382, 1960.
2. L. G. Christophorou (ed.), *Gaseous Dielectrics*, Volumes I-V, Pergamon Press, New York, respectively, 1978, 1980, 1982, 1984, 1987; Volumes VI and VII, Plenum Press, New York, respectively, 1990 and 1994.
3. Electric Power Research Institute, "Gases Superior to SF<sub>6</sub> for Insulation and Interruption," Report EPRI EL-2620, September, 1982.
4. S. A. Boggs, F. Y. Chu, and N. Fujimoto (eds.), *Gas-Insulated Substations*, Pergamon Press, New York, 1986.
5. W. T. Shugg, *Handbook of Electrical and Electronic Insulating Materials*, Second Edition, IEEE Press, New York, pp. 433-452, 1995.
6. L. G. Christophorou and R. J. Van Brunt, "SF<sub>6</sub>/N<sub>2</sub> Mixtures, Basic and HV Insulation Properties," *IEEE Trans. Dielectrics and Electrical Insulation*, Vol. 2, pp. 952-1003, 1995.
7. A. H. Cookson, "Gas-Insulated Cables," *IEEE Trans. Electr. Insul.*, Vol. EI-20, pp. 859-890, 1985.
8. G. R. Mitchell, J. Castonguay, and N. G. Trinh, in *Gas-Insulated Substations*, S. A. Boggs, F. Y. Chu, and N. Fujimoto (eds.), Pergamon Press, New York, 1986, p. 437.
9. G. Mauthe, L. Niemeyer, B. M. Pryor, R. Probst, H. Bräutigam, P. A. O'Connell, K. Pettersson, H. D. Morrison, J. Poblitzki, and D. Koenig, Task Force 01 of Working Group 23.10, "SF<sub>6</sub> and the Global Atmosphere," *Electra*, No. 164, pp. 121-131, February, 1996.
10. A. Diessner, CAPIEL draft paper on "The Influence of Switchgear on the Greenhouse Effect," private communication, 1996.
11. G. Mauthe, K. Pettersson, P. Probst, J. Poblitzki, D. Köning, L. Niemeyer, and B. M. Pryor, members of WG23.10 Task Force 01, draft document provided by Dr. M. Frechette (March, 1995).
12. E. Cook, "Lifetime Commitments: Why Climate Policymakers Can't Afford to Overlook Fully Fluorinated Compounds," *World Resources Institute*, Washington, DC, February, 1995.
13. L. G. Christophorou and R. J. Van Brunt, "SF<sub>6</sub> Insulation: Possible Greenhouse Problems and Solutions," *NISTIR 5685*, July 1995.
14. M. Maiss, and I. Levin, "Global Increase of SF<sub>6</sub> Observed in the Atmosphere," *Geophys. Res. Lett.*, Vol. 21, pp. 569-572, 1994.
15. C. P. Rinsland, M. R. Gunson, M. C. Abrams, L. L. Lowes, R. Zander, and E. Mahieu, "ATMOS/ATLAS 1 Measurements of Sulfur Hexafluoride (SF<sub>6</sub>) in the Lower Stratosphere and Upper Troposphere," *J. Geophys. Res.*, Vol. 98, pp. 20 491-20 494, 1993.
16. V. Ramanathan, L. Callis, R. Cess, J. Hansen, I. Isaksen, W. Kuhn, A. Lacis, F. Luther, J. Mahlman, R. Reck, and M. Schlesinger, "Climate-Chemical Interactions and Effects of Changing Atmospheric Trace Gases," *Reviews of Geophysics*, Vol. 25, pp. 1441-1482, 1987.
17. M. K. W. Ko, N. D. Sze, W.-C. Wang, G. Shia, A. Goldman, F. J. Murcray, D. G. Murcray, and C. P. Rinsland, "Atmospheric Sulfur Hexafluoride: Sources, Sinks and Greenhouse Warming," *J. Geophys. Res.*, Vol. 98, 10 499-10 507, 1993.
18. D. Edelson and K. B. McAfee, "Notes on the Infrared Spectrum of SF<sub>6</sub>," *J. Chem. Phys.*, Vol. 19, pp. 1311-1312, 1951.
19. Intergovernmental Panel on Climate Change (IPCC), "Radiative Forcing of Climate Change," The 1994 Report of the Scientific Assessment Working Group of IPCC, pp. 26-28.
20. U. S. Environmental Protection Agency, "Electrical Transmission and Distribution Systems, Sulfur Hexafluoride, and Atmospheric Effects of Greenhouse Gas Emissions Conference," *EPA Conference Proceedings Report*, August, 1995.
21. R. A. Morris, T. A. Miller, A. A. Viggiano, J. F. Paulson, S. Solomon, and G. Reid, "Effect of Electron and Ion Reactions on Atmospheric Lifetimes of Fully Fluorinated Compounds," *J. Geophysics Research*, Vol. 100, pp. 1287-1294, 1995.
22. D. J. Wuebbles and A. K. Jain, "Concerns About Climate Change and SF<sub>6</sub>," in [20], pp. 8-38.
23. Electricite de France, for example, is considering N<sub>2</sub> in insulated gas cables.
24. A. Gleizes, I. Sakalis, M. Razafimanana, and S. Vacquie, "Decay of Wall Stabilized Arcs in SF<sub>6</sub>-N<sub>2</sub> Mixtures," *J. Appl. Phys.*, Vol. 61, pp. 510-518, 1987.
25. A. Lee and L. S. Frost, "Interruption Capability of Gases and Gas Mixtures in a Puffer-Type Interrupter," *IEEE Trans. Plasma Science*, Vol. PS-8, pp. 362-367, 1980.
26. B. Chervy, H. Riad, A. Gleizes, and J. J. Gonzalez, "Interruption Capability of SF<sub>6</sub>-CF<sub>4</sub> and SF<sub>6</sub>-C<sub>2</sub>F<sub>6</sub> Mixtures," *Eleventh Intern. Conf. Gas Discharges and Their Applications*, pp. 1-334-1-337, Chuo University, Tokyo, Japan, 1995.