

NISTIR 6913

**Proposed Revisions of Part of the Test
Procedures for Furnaces and Boilers in
ASHRAE Standard 103-1993**

Stanley T. Liu

U.S DEPARTMENT OF COMMERCE
National Institute of Standard and Technology
Building Environment Division
Building and Fire Research Laboratory
Gaithersburg, MD 20899-8631

NET-

National Institute of Standards and Technology
Technology Administration, U.S. Department of Commerce

NISTIR 6913

**Proposed Revisions of Part of the Test
Procedures for Furnaces and Boilers in
ASHRAE Standard 103-1993**

Stanley T. Liu

U.S DEPARTMENT OF COMMERCE
National Institute of Standard and Technology
Building Environment Division
Building and Fire Research Laboratory
Gaithersburg, MD 20899-8631

September 2002



U.S. Department of Commerce
Donald L. Evans, Secretary

National Institute of Standards and Technology
Arden 1. Bement, Jr., Director

NISTIR 6913

**Proposed Revisions of Part of the Test
Procedures for Furnaces and Boilers in
ASHRAE Standard 103-1993**

Stanley T. Liu

U.S DEPARTMENT OF COMMERCE
National Institute of Standard and Technology
Building Environment Division
Building and Fire Research Laboratory
Gaithersburg, MD 20899-8631

NIST

National Institute of Standards and Technology
Technology Administration, U.S. Department of Commerce

NISTIR 6913

Proposed Revisions of Part of the Test Procedures for Furnaces and Boilers in ASHRAE Standard 103-1993

Stanley T. Liu

U.S DEPARTMENT OF COMMERCE
National Institute of Standard and Technology
Building Environment Division
Building and Fire Research Laboratory
Gaithersburg, MD 20899-8631

September 2002



U.S. **Department** of Commerce
Donald L. Evans, Secretary

National Institute of Standards and Technology
Arden I. Bement, Jr., Director

PROPOSED REVISIONS OF PART OF THE TEST PROCEDURES FOR FURNACES AND BOILERS IN ASHRAE STANDARD 103-1993

ABSTRACT

The U.S. Department of Energy's (DOE) procedure for testing the Annual Fuel Utilization Efficiency (AFUE) of residential central furnaces and boilers references ASHRAE Standard 103-1993. The standard has been used by the furnaceboiler industry to obtain the AFUE values of their products as required by DOE. ASHRAE Standard Project Committee (SPC) 103R is in the process of making revisions to the standard to address some shortcomings and to improve the calculation procedure on the basis of comments and experiences from the industry. This report presents proposed revisions to certain part of the test procedure to address some of the comments. The proposed revisions include a new procedure to calculate the average burner on/off times of modulating furnaces/boilers during the cyclic operation of the burner, a revised method for the calculation of the annual burner operating hours, and an extension of the procedure to calculate the off-period flue loss of oil-fired equipment designed with a long post purge time. This report also provides the background information on the derivation of the integral functions listed in Appendix E of ASHRAE Standard 103-1993 that have not been formally documented. Those integral functions were used for producing the graphs in the standard for the hand calculation of the off-period losses with a calculator, and also in the numerical algorithm in the computerized calculation procedure.

Key words: Annual energy consumption, Annual Fuel Utilization Efficiency, ASHRAE standard 103, burner operating hours, central furnace and boiler, DOE test procedure, integral functions for off-period losses, step-modulating furnaceshoilers, two-stage furnaceshoilers

ACKNOWLEDGMENTS

This study was sponsored by the U.S. Department of Energy, Office of Energy Efficiency and Renewable Energy.

Use of Non-SI Units in a NIST publication

The policy of the National Institute of Standards and Technology is to use the International System of Units (metric units) in all its publications. However, in North America in the construction and building materials industry, certain non-SI units are so widely used instead of SI units that it is more practical and less confusing to include measurement values for customary units only.

TABLE OF CONTENTS

	<u>Page</u>
ABSTRACT	iii
ACKNOWLEDGMENT	iv
TABLE OF CONTENTS	v
NOMENCLATURE	vi
1. INTRODUCTION	1
2. ON/OFF TIMES FOR MODULATING FURNACEBOILER	2
2.1 Background	2
2.2 AFUE Calculated by Current Test Procedure	2
2.3 Review of Current Procedure for Single Stage Furnaces/Boilers	4
2.4 Proposed Procedure for Modulating Furnaces/Boilers	5
2.5 Examples of AFUE Calculated on the Basis of Proposed Procedure	7
3. ANNUAL BURNER OPERATING HOURS AND ANNUAL ENERGY CONSUMPTION OF MODULATING FURNACES AND BOILERS	9
3.1 Background	9
3.2 Review of Test Procedure for Single Stage Furnaces/Boilers	10
3.3 Proposed Procedure for Modulating Furnaces/Boilers	11
3.3.1 Annual Burner Operating Hours	11
3.3.2 Annual Fuel Energy Consumption	13
3.3.3 Annual Auxiliary Electrical Energy Consumption	13
3.3.4 Units with Standing Pilot Light	14
4. CALCULATION OF OFF-PERIOD LOSSES FOR OIL-FIRED BOILERS WITH LONG POST PURGE TIME	15
4.1 Background	15
4.2 Calculation Procedure for Losses during Post Purge Period	15
4.2.1 Assumptions	15
4.2.2 Calculation for Sensible Loss	15
4.2.3 Calculation for Infiltration Loss	17
5. INFORMATION ON THE DERIVATION OF THE INTEGRAL FUNCTIONS FOR CALCULATING THE OFF-PERIODLOSSES IN ASHRAE 103-1993	17
5.1 Background	17
5.2 Derivation of the Integral Functions	18
6. SUMMARY	21
REFERENCES	22

NOMENCLATURE

XFUE	annual fuel utilization efficiency in percent
A/F	mass ratio of stoichiometric air to fuel
BE	electrical power (kW) to circulation air blower or water pump
BOH	number of annual burner operating hours
BOH _H	number of burner operating hours at maximum fuel input rate
BOH _M	number of burner operating hours at modulating fuel input mode
BOH _R	number of burner operating hours at reduced fuel input rate
C _P	specific heat of air
C _{T,OFF}	cool-down temperature profile correction factor for the effect of cycling
D _F	off-cycle draft factor for flue gas flow
DHR	design heating requirement
D _P	power burner draft factor
E _F	annual fuel energy consumption
E _{AE}	annual electric energy consumption
Effy _{HS}	heating seasonal efficiency in percent
Effy _{SS}	steady-state efficiency in percent
Effy _{SS,M}	average steady-state efficiency operating in modulating mode in percent
F3, F4, F5	
F6, F7, F8	off-cycle sensible heat loss integration factors
HHV	higher heating value of fuel
HLH	heating load hours
K _{S,OFF}	multiplication factor for sensible heat loss during the off-period
L _{I,OFF}	off-cycle infiltration loss in percent
L _{S,OFF}	off-cycle sensible heat loss in percent
M _{F,OFF}	off-cycle flue gas mass flow rate (per minute)
M _{F,ON}	on-cycle flue gas mass flow rate (per minute)
N	number of burner cycles per hour based on the response of thermostat at half load
PE	electrical power (kW) to burner
Q _{IN}	steady-state rated (maximum) fuel input rate (per hour)
Q _{IN,H}	steady-state maximum fuel input rate (per hour) for a modulating unit
Q _{IN,R}	steady-state reduced (minimum) fuel input rate (per hour)
Q _{OUT}	heating capacity, useful heat output per hour, under steady-state rated fuel input
Q _{OUT,M}	average heat output rate (per hour) for modulating mode
Q _{OUT,R}	heating capacity, at reduced (minimum) fuel input rate
QP	fuel energy input per hour to pilot light
t	time in minute
t _P	power burner post-purge time period
t _{OFF}	burner off-time per cycle
t _{ON}	burner on-time per cycle
T _C	balance point temperature for modulating units
T _D	design outdoor air temperature
T _{F,OFF(t)}	off-period flue gas temperature at time t
T _{F,SS}	steady-state flue gas temperature

T_{OA}	average outdoor air temperature
$T_{OA,H}$	average outdoor air temperature at maximum input operating mode
$T_{OA,R}$	average outdoor air temperature at reduced input operating mode
T_{RA}	laboratory room temperature
T_{REF}	a reference air temperature
$V_{F,OFF}$	off-period flue gas volume flow rate in minute
$V_{F,ON}$	on-period flue gas volume flow rate in minute
X	load factor, single-stage unit
X_h	load factor when operating at maximum fuel input rate
X_r	load factor when operating at reduced fuel input rate
X_H	fraction of heating load at maximum fuel input operating mode
X_R	fraction of heating load at reduced fuel input operating mode
ν	ratio of circulation air blower or pump on-time to burner on-time
a	oversize factor, rated heating capacity to design heating requirement (DHR)
α_R	oversize factor, heating capacity at reduced input rate to DHR
Δt	time interval
ρ_F	density of flue gas
τ_{OFF}	off-cycle time constant

1. INTRODUCTION

The U.S. Department of Energy (DOE) test procedure ^[1] for determining the Annual Fuel Utilization Efficiency (AFUE) of residential central furnaces and boilers referenced the industry test standard ANSI/ASHRAE 103-1993 ^[2] (ASHRAE 103-1993) of the American Society of Heating, Refrigerating, and Air Conditioning Engineers (ASHRAE). The standard was initially developed in 1982 based on the DOE test procedures for single stage furnaces and boilers recommended by Kelly et al ^[3]. It was subsequently revised in 1988 and again in 1993 to include test procedures for condensing units, modulating (or multi-fire) units, and for units employing a short post-purge period after the burner is shut off. In 1998 ASHRAE organized the Standard Project Committee (SPC) 103R to begin the revision process to ASHRAE 103-1993 following comments from the industry on the need to address some possible shortcomings of the standard based on user experiences. This report documents the proposals to SPC-103R to address the issues raised by industry concerning the test standard. The issues are as following:

(1) The inconsistency in the calculated AFUE values for a two-stage furnace (or boiler) when they are calculated on the basis of (a) the single-stage procedure and (b) the modulating two-stage procedure using the same test data. The first one treats the furnace **as** a single stage furnace operating at the reduced input to supply the heating load, and the second one treats the furnace as two-stage furnace. With a ratio of reduced input to rated input of from 60 % to 70 %, the standard shows that the furnace would supply almost 98 % of the annual heating load at the reduced input. That is, the furnace is operating as a single-stage furnace at the reduced fuel input rate most of the time even when it is treated as a two-stage furnace. However, the calculated results showed a difference in the AFUE values of more than one percentage point between the two procedures.

(2) In the calculation for the number of annual Burner Operating Hours (BOH) for a modulating furnace (or boiler), the standard estimates the BOH using the fuel and auxiliary electric energy input measured at the maximum rated input condition. For a two-stage furnace, the major portion of the heating load is supplied at the reduced input, with the auxiliary electrical components also operating under the settings for the reduced input rate.

(3) For units employing post purge after the burner is shut off, the standard provides a calculation procedure that limits the post purge time *to* three minutes. For some oil-fired boilers that require a longer post purge time, the formula in the standard will produce erroneous (smaller) flue loss result.

(4) The standard listed a group of integral functions named as F3 to F8 that were used to produce the graphs in the standard for hand calculation of the off-period losses, and in the numerical algorithm for the losses in a computerized calculation procedure. There is no documentation on the derivation of those functions. A search of the publications ^[3, 4] where the functions were first presented did not show the procedure or provide information about how the functions were derived.

This report presents a proposed revision to the burner on/off times for a modulating appliance that corrected the inconsistency problem in AFUE, and a revised BOH calculation procedure for a modulating appliance that uses the measured fuel and auxiliary electric inputs at the actual operating conditions. The annual fuel and electric energy consumption are calculated on the basis of the BOH. A procedure for the post purge calculation beyond three minutes is derived, and the background information of the process in the derivation of the integral functions F3 to F6 is shown.

2. ON/OFF TIMES FOR MODULATING FURNACE/BOILER

2.1 Background

The current test procedure in ASHRAE 103-1993 prescribes the calculation of the AFUE of a single stage furnace by using test data from the steady state, cool down and heat up tests at the rated input. In the calculation procedure, the average furnace cycling on/off times are assumed to be 3.87 min on and 13.3 min off based on the characteristic responses of the room thermostat and a furnace oversize factor of 0.7 with respect to the building heating load. This results in the furnace operating at an average of 22.5 % of the rated capacity during the heating season. The AFUE of a two-stage furnace is calculated by using test data from the steady state, cool down and heat up tests at both the maximum (high) input rate and at the minimum (low) input rate. There the average furnace cycling on/off time are assumed to be 10min on and 10min off. And this assumes the two-stage furnace operating at an average of 50 % of the rated capacity during the heating season.

During the past years, a discrepancy in the calculation procedure was discovered with respect to some modulating furnaces. The AFUE value for the furnaces operating as a two-stage furnace was lower than the value when the same test data were used in a calculation with the furnace operating as a single stage furnace operating under low firing rate. These furnaces were non-condensing two-stage furnaces with a low fire to high fire ratio of 0.60 to 0.70 that are typical of two-stage furnaces. The difference in the AFUE values between the two calculations (modulating procedure versus single stage procedure) can be more than 1 percentage point. However, based on the test procedure, a two-stage furnace with a ratio of low to high firing rates of 0.65 would operate in the low firing rate to meet more than 95 % of the annual heating load in a heating season. Therefore, the resulting AFUE was expected to be close to the value calculated on the basis of single-stage firing at the low rate over the entire heating season. The question was raised as to the reason for this one percentage point discrepancy in the AFUE values.

2.2 AFUE Calculated by Current Test Procedure

Using test data of a two-stage furnace, NIST investigated the cause of this discrepancy using the computer program AFUEBF (a computerized version of the calculation procedure of ASHRAE 103-1993). The *original* version and a slightly modified version of the program were run using the same test data as input. The modified version changed (only) the furnace on/off times to examine the effect of the changes in the on/off times. The changes made on the on/off times were (1) 3.87/13.3 min for both single stage and two-stage calculation, and (2) 10/10 min for

both single stage and two-stage calculation. It was found that the discrepancy in the AFUE described above was caused by the difference in the on/off times assigned to a single stage furnace versus to a two-stage furnace. The following examples show the results (AFUE) of two gas-fired, two-stage non-condensing furnaces using test data from a manufacturer. Both have a low fire to high fire input ratio of 0.65. The maximum input of Example 1 is 80 000 Btu/h. The maximum input of Example 2 is 60 000 Btu/h.

Example 1:

AFUE Value

On/Off Time*	Using Single Stage Calculation		Using Two-Stage Calculation		Weighted Average
	High-Fire	Low-Fire	High-Fire	Low-Fire	
3.87/13.3	82.64	81.99	82.10	81.85	81.85
10.0/10.0	82.37	81.59	81.50	81.53	81.52

*Note: Current on/off times are 3.87/13.3 min for single stage furnace, 10/10 min for two-stage furnace. Value in bold type indicates result by current procedure for modulating furnace.

Example 2:

AFUE Value

On/Off Time*	Using Single Stage Calculation		Using Two-Stage Calculation		Weighted Average
	High-Fire	Low-Fire	High-Fire	Low-Fire	
3.87/13.3	82.32	81.31	81.79	81.35	81.35
10.0/10.0	81.50	80.33	80.34	80.32	80.34

*Note: Current on/off times are 3.87/13.3 min for single stage furnace, 10/10 min for two-stage furnace. Value in bold type indicates result based on current procedure for modulating furnace.

Example 1 shows that the current calculation procedure for a two-stage furnace gives a lower AFUE value (81.52 %) than if the furnace were operating as a single stage furnace (where the on/off times are set at 3.87/13.3 min) at either high or low firing rates (AFUE of 82.64 % and 81.99 %, respectively). When the on/off times were changed to 10.0/10.0 min for the low-firing, single stage case, the calculated AFUE became 81.59 % which is closer to the 81.52 % for the weighted two-stage result at the same 10.0/10.0 on/off times. (From ASHRAE 103-1993, the weighting factor for the two-stage calculation is greater than 0.95 at low fire and less than 0.05 at high fire - that is, the two-stage furnace operated almost all under low fire to meet the annual heating load). The same close agreement happens if the on/off times are 3.87/13.3 min for both single and two-stage calculation (81.99 % under single stage low fire and 81.85 % under two-

stage). Example 2 is from test data of another (smaller capacity) furnace. The results of this example show that the discrepancy under the current calculation procedure could be 1 percentage point in favor of the single stage calculation.

As described above, the discrepancy in the results in the current calculation procedure is caused by the difference in the assigned on/off times for the two types (single stage versus modulating) of furnaces. A possible revision would be to change the assigned on/off times to some more appropriate values. The problem is to determine what should be the corrected on/off times for a modulating furnace, or a modulating boiler (where on/off times are specified as 15/15 min in the present procedure).

Section 2.3 describes the current procedures for determining on/off times. Section 2.4 describes the proposed procedure for determining the on/off times for a modulating furnace/boiler based on its minimum (low-fire) to maximum (high-fire) capacity ratio.

2.3 Review of Current Procedure for Single Stage Furnaces/Boilers

In the development of the original test procedure for a single stage unit, the on and off times of a furnace/boiler are calculated by the following equations [3].

$$t_{ON} = \frac{60 X}{4 N X (1 - X)} \quad (2-1)$$

$$t_{OFF} = \frac{60}{4 N X (1 - X)} - t_{ON} \quad (2-2)$$

where

N = number of burner cycles per hour based on the responses of thermostat at half load,
 = 5 for furnace
 = 2 for boiler

X is the load factor and is defined as:

$$X = \frac{65 - T_{OA}}{65 - T_D} \frac{1}{1 + \alpha} \quad (2-3)$$

where

T_{OA} = the average outdoor temperature. ($T_{OA} = 42^{\circ}\text{F}$ in the test procedure)
 T_D = the outdoor design temperature. ($T_D = 5^{\circ}\text{F}$ in the test procedure)
 α = oversize factor = 0.7 for a single stage unit

For a single stage unit, $X = 0.225$, based on the values of T_{OA} , T_D , and α in the test procedure. This resulted in the values of t_{ON}/t_{OFF} of 3.87/13.3 min as given in the test procedure.

2.4 Proposed Procedure for Modulating Furnaces/Boilers

For a modulating furnace or boiler, the current test procedure assumed a load factor of $X = 0.5$ which would give the on/off times of 6/6 min ($N = 5$) for furnaces and 15/15 min ($N=2$) for boilers. However, the actual on/off times for furnaces in ASHRAE 103-1993 was set at 10/10 instead of 6/6. A detailed description and the rationale for the setting of on/off times for modulating furnaces/boilers in the current test standard was presented in reference [5]. However, since a modulating furnace (or boiler) does not always have the specific minimum input rate that would result in $X = 0.5$ when the unit is operating in the minimum input rate, the on/off times actually vary depending on the ratio of the minimum to maximum input rates.

For modulating furnaces/boilers, ASHRAE 103-1993 defined a balance point temperature T_C as the change over temperature for the unit to switch from the minimum input rate to the modulating input or the maximum input rate. The balance point temperature is defined as the value of the outdoor temperature above which the modulating equipment is capable of providing the building heating load requirement at the minimum or low input rate. For outdoor temperature below the balance point temperature, the unit will switch to its modulating mode of operation for step-modulating units or to its maximum input rate for a two-stage unit. In ASHRAE 103-1993, The balance point temperature is calculated as,

$$T_C = 65 - (60)(1 + \alpha) \frac{Q_{OUT,R}}{Q_{OUT}} \quad (2-4)$$

Where $Q_{OUT,R}/Q_{OUT}$ is the minimum to maximum capacity ratio of the modulating unit. $\alpha = 0.7$ is the oversize factor at the maximum input rate of the modulating unit. It is seen that the value of T_C depends on the ratio of the minimum to maximum capacity ratio. With $\alpha = 0.7$ and a capacity ratio of approximately 0.5884, T_C would be equal to approximately 5 °F, the average outdoor design temperature. This means that for a furnace/boiler with a capacity ratio of greater than or equal to 0.5884, the furnace/boiler will operate in the minimum (low) firing rate for the entire heating season. For values of the capacity ratio less than 0.5884, T_C would have a value of between 5 °F and 65 °F. In this range, the modulating unit will operate in the low firing rate when the outdoor temperature is between T_C and 65 °F. The unit will switch to the maximum (high) firing rate (two-stage control) or to the intermediate (step-up) firing rates (step-modulating control) when the outdoor temperature is between the design temperature of 5 °F and T_C . ASHRAE 103-1993 provides graphs to determine the fractions of the annual heating load X_R and X_H (as functions of T_C) that will be supplied by the modulating equipment operating at the minimum (low) and the maximum (high) firing rates, respectively. The standard also gives the values of the average outdoor temperatures $T_{OA,R}$ (between T_C and 65 °F in low firing rate operation) and $T_{OA,H}$ (between 5 °F and T_C in high firing rate operation), as function of T_C . These temperatures are equivalent to the T_{OA} of 42 °F for the single stage equipment.

For the values of the capacity ratio (low fire to high fire) greater than approximately 0.59, the modulating furnace/boiler operates mostly in the low firing rate. If, as assumed, the oversize

factor a of the unit operating at the high firing rate is at 0.7. an oversize factor α_R at the minimum firing rate with respect to the building design heating load can be defined as,

$$1 + \alpha_R = \frac{Q_{OUT.R}}{DHR}$$

where,

α_R = the oversize factor at the reduced input rate,

DHR = Design Heating Requirement.

As stated before, at the maximum firing rate, the oversize factor a is defined as,

$$1 + \alpha = \frac{Q_{OUT}}{DHR}$$

Combining the above two expressions results in,

$$1 + \alpha_R = (1 + \alpha) \frac{Q_{OUT.R}}{Q_{OUT}} \quad (2-5)$$

It was noted at the meetings of the multi-fire working group of ASHRAE SPC 103R that at the values of $a = 0.7$ and $Q_{OUT.R} / Q_{OUT}$ of approximately 0.59, the unit is no longer oversized at the minimum firing rate ($\alpha_R \cong 0$). Therefore, equation (2-5) holds for values of a and the capacity ratio that give a value of α_R equal or greater than 0.

With the calculated α_R from equation (2-5), equation (2-3) for the load factor X can be used to calculate a load factor X_r at the minimum input and a load factor X_h at the maximum input rate, as,

$$X_r = \frac{65 - T_{OA.R}}{65 - T_C} \frac{1}{1 + \alpha_R}, \quad (\alpha_R \geq 0.) \quad (2-6)$$

$$X_h = \frac{65 - T_{OA.H}}{65 - T_D} \frac{1}{1 + \alpha} \quad (2-7)$$

It was noted at the meetings of the multi-fire working group of ASHRAE SPC 103R that the minimum outdoor temperature for the load factor X_r is T_C , not the design temperature T_D , since T_C is the limiting low outdoor temperature for the modulating unit to operate in low firing rate.

In ASHRAE 103-1993 only the on/off times based on the low firing rate is used in the calculation procedure. This is because that, for the majority of modulating units, the requirement of optimum fuel to air ratio under all firing rates results in the capacity ratio of low to high firing of from 0.4 to 0.7. In this range, from 80 % to 99% of the annual heating load are met by the

modulating unit operating at low fire. Employing the same approach, equation (2-6), in place of equation (2-3), can be used to calculate the load factor X. The on/off times of equations (2-1) and (2-2) for the modulating unit can then be calculated based on the value of X from equation (2-6). The calculated on/off times are then used in the calculating procedure for modulating furnaces or boilers. The following table shows the calculated on/off times for a modulating furnace (with N=5) and a modulating boiler (N=2), at capacity ratios of 0.4 to 0.75, where 0.75 is the highest ratio defined in ASHRAE 103-1993 for modulating units. The two columns in the table labeled "(N=3)" showed the values of t_{ON} and t_{OFF} for the case that the value of N is assumed to be 3 instead of 5 for modulating furnaces. The value N=3 resulted from the approximation of the on/off of 10/10 for modulating furnaces in ASHRAE 103-1993:

Modulated Furnace On/Off Times Based on $Q_{OUT,R}/Q_{OUT}$

Capacity Ratio	T_C °F	$1+\alpha_R$	$T_{OA,R}^*$ °F	$T_{OA,H}^*$ °F	X_R^*	$X=X_r$ Load Factor	t_{ON} (min) (N = 5)	t_{OFF} (min)	t_{ON} (min) (N = 3)	t_{OFF} (min)	t_{ON} (min) (N = 2)	t_{OFF} (min)	
0.40	24.2	1.0	43.5	19	0.83	0.527	6.34	5.69	10.57	9.49	15.85	14.23	
0.45	19.1	1.0	42.6	15	0.89	0.488	5.86	6.15	9.77	10.25	14.65	15.37	
0.50	14.0	1.0	41.8	11	0.94	0.455	5.50	6.59	9.17	10.99	13.76	16.49	
0.55	8.9	1.0	41.0	7.5	0.97	0.428	5.24	7.01	8.74	11.69	13.11	17.53	
0.60	5	1.02	40.7	5	0.99	0.397	4.98	7.56	8.29	12.59	12.44	18.89	
0.65	5	1.11	40.7	5	0.99	0.367	4.74	8.19	7.89	13.64	11.84	20.46	
0.70	5	1.19	40.7	5	0.99	0.340	4.55	8.81	7.58	14.69	11.37	22.04	
0.75	5	1.26	40.7	5	0.99	0.318	4.40	9.44	7.33	15.74	10.99	23.61	
Single Stage (specified in ASHRAE 103)							0.225	3.87	13.33	--	--	9.68	33.26

*Note: The values of $T_{OA,R}$ (average outdoor temperature at minimum input), $T_{OA,H}$ (average outdoor temperature at maximum input), and X_R (the fraction of annual heating load supplied at the minimum input) as function of T_C are from Figures 23 and 24 of ASHRAE 103-1993^[2].

For comparison, the last row in the above table listed the values of the load factor X and the burner on/off times for a single stage furnace (with N = 5) and a single stage boiler (with N = 2) as specified in ASHRAE 103-1993.

2.5 Examples of AFUE Calculated on the Basis of Proposed Procedure

The following are two examples of using the calculated on/off times (with N = 5) in the AFUE calculation for the two-stage furnace examples shown previously. In place of the fixed on/off values of 10/10 (minutes) for the furnace, the values were calculated using equations 2-1, 2-2, and 2-6) on the basis of the capacity ratio $Q_{OUT,R}/Q_{OUT}$. The capacity ratio was computed based on data from the steady states test.

Example 1:

AFUE Value

On/Off Times (min)	Single Stage Calculation		Two-Stage Calculation		Weighted Average
	High-Fire Test Data	Low-Fire Test Data	High-Fire Test Data	Low-Fire Test Data	
3.87/13.3	82.64	81.99			
10.0/10.0			81.50	81.53	81.52
4.59/8.67 (Calculated)			81.90	81.70	81.71

Example 2:

AFUE Value

On/Off Times (min)	Single Stage Calculation		Two-Stage Calculation		Weighted Average
	High-Fire Test Data	Low-Fire Test Data	High-Fire Test Data	Low-Fire Test Data	
3.87/13.3	82.32	81.31			
10.0/10.0			80.34	80.32	80.34
4.58/8.69 (Calculated)			81.38	80.91	80.94

In example 1, the calculated AFUE is 81.99% based on single-stage at low fire at the existing ordoff times, and 81.71 % based on two-stage with the new ordoff times. For the second furnace, the comparison is 81.31 % to 80.94 %. It is noted that even though the differences are smaller, the results still do not agree with each other exactly. This is because that for single-stage low-fire, the on/off times really should not be 3.87/13.3 but instead should be approximately 4.6/8.7 since at the low firing rate, the oversize factor is not 0.7, but a smaller value of approximately $\alpha_R = 0.11$ (see previous table on the value of $(1 + \alpha_R = 1.11)$ at $Q_{OUT,R} / Q_{OUT}$ of 0.65). If the ordoff values of 4.6/8.7 are used in the single-stage calculation, the result would be very close to the two-stage procedure since in the two-stage operation, 99 % of the annual heating load is met by the furnace operating under low-fire.

Lastly, it is noted that in the above proposal, the ordoff times based on the low-fire condition are used for the high-fire portion of the calculation also. This is a simplification based on the reason that the fraction of high fire condition is small in the practical range of the capacity ratios from 0.40 to 0.75. If more precision in the result is desired, separate load factors for X_h and X_r can be calculated from equations (2-6) and (2-7), and they in turn can be used to calculate the separate ordoff times for low fire and high fire conditions from equations (2-1) and (2-2). However, as stated before, it is considered at the present time to be not necessary for the range of capacity ratios encountered in practice.

3. ANNUAL BURNER OPERATING HOURS (BOH) AND ANNUAL ENERGY CONSUMPTION OF MODULATING FURNACES AND BOILERS

3.1 Background

In the existing ASHRAE 103-1993/DOE test procedure ^[1, 2], an equivalent number of burner operating hours (BOH_{SS}) based on operation condition at the maximum rated input was defined to estimate the annual fuel energy consumption of both the single-stage and the modulating furnaces/boilers. For single stage units, the formulation is straightforward. The number of burner operating hours is calculated as the annual building load divided by the useful outputs of the furnaceboiler delivered to the conditioned space. The useful output energy from the furnaceboiler composed of the heat output from the burning of fuel at the heating seasonal efficiency plus the heat from the electrical power input to the auxiliary electric equipment. The annual fuel energy consumption is calculated as the number of burner operating hour times the rated energy input plus the off-period pilot light consumption if employed. For modulating furnaceboiler, the same formulation is retained. However, in the BOH_{SS} formula, a multiplication factor $R = 2.3$ or 3.0 (depending on the capacity ratio of minimum (low-fire) to maximum (high-fire)) is introduced in the auxiliary electrical power term. The heat energy output from the fuel is calculated as the maximum rated input at the weighted heating seasonal efficiency of the modulating furnaceboiler. The purpose of the factor R was to account for the greater on-time fraction per cycle (0.50) for modulating unit as compared to the on-time fraction per cycle (0.225) for single stage unit. The ratio of 0.50 to 0.225 results in R as 2.30 . The assumption was that the auxiliary electrical energy consumption of the modulating furnaceboiler due to the assumed larger fraction on time per cycle would be approximated by the multiplication factor 2.3 to the auxiliary electrical power input of air circulation blowers and power burners, etc. Since the maximum fuel input rate and the steady-state auxiliary electrical power input measured at the maximum firing rate are used *to* compute the BOH_{SS} , the term no longer represents the actual annual burner operating hours of the equipment which mostly operated in the reduced or modulating input mode. Rather, it is used as an equivalent BOH_{SS} term to approximate or estimate the annual fuel energy consumption of the modulating equipment during a heating season. (Appendix C of ASHRAE 103-1993.) However, these assumptions ignored the effects of the possible different values of the electrical power input at the maximum and reduced fuel input rates for furnaceshoilers with a variable speed circulating air blower and combustion blower. Also, the use of the maximum fuel input rate in the calculation formula for the BOH_{SS} causes confusion to users of the standard since for a modulating furnaceboiler, the design purpose is for the equipment to operate at the reduced input rate most of the heating season.

To improve upon the above-mentioned assumptions in the calculation procedure, the proposed calculation procedure would use the actual power inputs of a variable speed blower at the firing rates it is operating under. The actual burner operating hours at the maximum input and the reduced (minimum) input rates are calculated to determine the annual energy consumption of the equipment operating under both modes. The procedure would also use both the maximum and

the reduced fuel input rates in the calculation of the burner operating hours under each firing rate to eliminate the approximation of an equivalent BOH_{SS} .

3.2 Review of Test Procedure for Single Stage Furnaces/Boilers

From Appendix A of NBSIR 78-1543^[3] or Appendix C of ASHRAE 103-1993^[2], the number of Burner Operating Hours (BOH) and the annual fuel consumption E_F for a single stage furnace are calculated as, for indoor installation,

$$BOH = [\text{Heating Season Fuel Consumed} - (Q_P)(\text{Heating Season Hour})] / Q_{IN},$$

$$\begin{aligned} E_F &= \text{Annual Fuel Energy Consumption} \\ &= \text{Heating Season Fuel Consumed} + (Q_P)(\text{Non-Heating Season Hours}), \end{aligned}$$

$$\text{Heating Season Fuel Consumed} = [\text{Annual Building Load} - (PE + y BE)(BOH)] / \text{Effy}_{HS},$$

$$\text{Annual Building Load} = (C)(HLH)(DHR),$$

where,

- Q_{IN} = steady-state rated fuel energy input
- Q_P = pilot light fuel consumption rate
- BE = electric power to circulation blower or water pump
- PE = electric power to burner
- y = ratio of circulation blower or pump on-time to burner on-time in a burner cycle
- Effy_{HS} = heating seasonal efficiency
- HLH = Heating Load Hours
- DHR = design heating requirement of a building
- C = 0.77, an adjustment factor defined in Appendix C of ASHRAE 103-1993.

For uniform rating purpose, ASHRAE 103-1993 established the following national average values for some of the weather-related parameters:

- Non-Heating Season Hours = 4600,
- Heating Season Hours = 4160,
- Heating Load Hours (HLH) = 2080.

For simplicity, let $E_p = [(PE) + (y)(BE)]$, $\eta_u = \text{Effy}_{HS}$, and using the national average values,

$$\begin{aligned} BOH &= HLH [(C)(A)(DHR) - B] = 2080 [(C)(A)(DHR) - B], & (3-1) \\ A &= 1 / [E_p + (Q_{IN} - Q_P) \eta_u], \\ B &= (Q_P)(\eta_u)(A)(\text{Heating Season Hours}) / HLH = 2 Q_P \eta_u A \end{aligned}$$

The above equations are the same as those given in Appendix C of ASHRAE 103-1993, except that for simplicity, the percent and unit conversion factors (100 in percent and $3413 \text{ W} = 1 \text{ Btu/h}$) spelled out in the equations in ASHRAE 103-1993 are not included here. (For use in actual

calculation with numbers, consistency in units with the appropriate unit conversion factors is needed and included in the equations in the standard.)

3.3 Proposed Procedure for Modulating Furnaces/Boilers

3.3.1 Annual Burner Operating Hours (BOH):

The following nomenclature is used in the derivation of the proposed procedure:

BOH_H = annual BOH of a two-stage unit at the maximum rated input $Q_{IN,H}$

$Q_{IN,H}$ = fuel input rate at the maximum firing rate

E_{PH} = electric power consumption measured under steady state at input $Q_{IN,H}$

$\eta_{u,H}$ = part-load efficiency of a two-stage unit operating at input $Q_{IN,H}$

BOH_M = annual burner operating hours of a step-modulating unit at modulating mode

$Q_{IN,M}$ = fuel input rate in the modulating mode of a step-modulating unit as calculated in sec.1, Appendix C of ASHRAE 103-1993

E_{PM} = electric power input of a step-modulating unit operating in the modulating mode and measured under steady state at input $Q_{IN,H}$

$\eta_{u,M}$ = average part-load efficiency of a step-modulating furnaceboiler operating in the modulating mode (Sec. 11.4.9.2.3, ASHRAE 103-1993)

BOH_R = annual burner operating hours at the minimum input $Q_{IN,R}$

$Q_{IN,R}$ = fuel input rate at the minimum firing rate

E_{PR} = electric power input measured under steady state at input $Q_{IN,R}$

$\eta_{u,R}$ = part-load efficiency operating at input $Q_{IN,R}$

It is assumed that for the modulating furnaceboiler operating at either the maximum or minimum input, or at modulating mode, the Design Heating Requirement (DHR) of the building is not changed and therefore the required furnaceboiler heat output to meet the DHR of the building is not changed.

For simplicity in showing the derivation process, it is assumed that the modulating unit has an electric ignition device so that the pilot $Q_P = 0$ (extension of results to include Q_P will be shown later in this report). With this assumption, the general equations for the BOH (Eq.3-1) and the variables A and B of Section 3.2 above are reduced to:

$$B = 0,$$

$$A = 1 / [E_p + (Q_{IN}) \eta_u]$$

and

$$BOH = 2080 [(C)(A)(DHR)]. \tag{3-2}$$

With the above assumptions, the burner operation hours in meeting the total annual heating load under the maximum firing rate is,

$$\text{BOH}_H^* = \text{HLH} [(C)(A_H)(\text{DHR})],$$

$$A_H = 1 / [\text{Ep}_H + (Q_{\text{IN},H}) \eta_{u,H}]$$

where the asterisk * indicates the total BOH if the appliance operates at a particular (maximum here) firing rate for the entire heating season. If only a fraction of the total annual heating load is met by the appliance operating at the maximum firing rate, the actual BOH at the maximum firing rate (for a two-stage unit) during the heating season will be,

$$\text{BOH}_H = (X_H) (\text{BOH}_H^*) = (X_H)[(C)(\text{HLH})(A_H)(\text{DHR})], \quad (3-3)$$

where X_H is defined in Sec. 11.4.8.6 of ASHRAE 103-1993 as the fraction of the total annual heating load that is provided by a two-stage appliance at the maximum firing rate.

Similarly, the total burner operating hours to satisfy the total annual heating load when operating under the minimum firing rate for the entire heating season is,

$$\text{BOH}_R^* = \text{HLH} [(C)(A_R)(\text{DHR})],$$

$$A_R = 1 / [\text{Ep}_R + (Q_{\text{IN},R}) \eta_{u,R}].$$

And, if only a fraction of the total annual heating load is met by the appliance operating at the minimum firing rate, the BOH at the minimum firing rate during the heating season will be,

$$\text{BOH}_R = (X_R) (\text{BOH}_R^*) = (X_R)[2080 (C)(A_R)(\text{DHR})], \quad (3-4)$$

where X_R is defined in Sec. 11.4.8.7 of ASHRAE 103-1993 as the fraction of the total annual heating load that is provided by a modulating appliance at the minimum firing rate.

For a step-modulating furnaceboiler, the fuel input rate at the modulating mode is not measured in ASHRAE 103-1993 since the firing rate at the modulating mode varies and cannot be determined a priori. Instead, ASHRAE 103-1993 calculates a $Q_{\text{IN},M}$ as,

$$Q_{\text{IN},M} = Q_{\text{OUT},M} / \text{Eff}_{\text{SS},M}, \quad (\text{From Sec. 1 of Appendix C, ASHRAE 103-1993})$$

where

$\text{Eff}_{\text{SS},M}$ = average steady-state efficiency calculated in Sec. 11.4.8.8 of ASHRAE 103-1993

$Q_{\text{OUT},M}$ = average heat output rate calculated in Sec. 11.4.8.10 of ASHRAE 103-1993

The fraction of the total annual heating load that is provided by a step-modulating appliance in the modulating mode, X_M , is assumed in ASHRAE 103-1993 to equal $(1 - X_R)$. That is, the modulating mode is at any input rate greater than the minimum input rate. Also, the electrical power inputs to the step-modulating appliance in the modulating mode (BE_M and PE_M) are not measured in ASHRAE 103-1993 and are assumed to be those measured during the steady-state test at the maximum fuel input rate, that is, $\text{Ep}_M = \text{Ep}_H$. Therefore, the burner operating hours for a step-modulating appliance operating in the modulating mode during the heating season is,

$$BOH_M = (X_H)[2080 (C)(A_M)(DHR)], \quad (3-5)$$

where

$$A_M = 1 / [E_{pH} + (Q_{IN,M}) \eta_{u,M}]$$

In the above formulation, the subscripts H, M and R denote the values at the maximum firing rate, the modulating mode (step-modulating), and the minimum firing rate, respectively. The variables E_{pH} , E_{pR} , $Q_{IN,H}$, $Q_{IN,R}$, $Q_{IN,M}$, $\eta_{u,H}$, $\eta_{u,R}$ and $\eta_{u,M}$ are defined previously.

3.3.2 Annual Fuel Energy Consumption

For two-stage modulating appliances, the annual heating load is met by the appliance operating at either the minimum firing rate or at the maximum firing rate. Therefore, the annual fuel energy consumption for a two-stage appliance is,

$$E_F = (BOH_H)(Q_{IN,H}) + (BOH_R)(Q_{IN,R}). \quad (3-6)$$

For step-modulating appliance, the total annual heating load is met by the appliance operating at either the minimum firing rate or at the modulating mode (up to the maximum firing rate). Therefore, the annual fuel energy consumption for a step-modulating appliance is,

$$E_F = (BOH_M)(Q_{IN,M}) + (BOH_R)(Q_{IN,R}). \quad (3-7)$$

3.3.3 Annual Auxiliary Electrical Energy Consumption

The annual auxiliary electrical energy consumption for a two-stage appliance is,

$$E_{AE} = (BOH_H)(E_{pH}) + (BOH_R)(E_{pR}) \quad (3-8)$$

The annual auxiliary electrical energy consumption for a step-modulating appliance is,

$$E_{AE} = (BOH_M)(E_{pH}) + (BOH_R)(E_{pR}). \quad (3-9)$$

In the general form without the subscript, $E_p = (BE) + (y)(PE)$, as defined previously.

3.3.4 Units with Standing Pilot Light

It is assumed previously that the modulating appliance employs interrupted electronic ignition and no pilot light is needed. If the modulating appliance has a continuing burning pilot light with fuel input rate Q_p , the above formulation should be modified by setting the parameters A_H , A_R , A_M and B_H , B_R , B_M as

$$A_H = 1 / [E_{pH} + (Q_{IN,H} - Q_p) \eta_{u,H}],$$

$$A_R = 1 / [E_{pR} + (Q_{IN,R} - Q_p) \eta_{u,R}],$$

$$A_M = 1 / [E_{PH} + (Q_{IN,M} - Q_P) \eta_{u,M}]$$

$$B_H = 2 Q_P \eta_{u,H} A_H,$$

$$B_R = 2 Q_P \eta_{u,R} A_R,$$

$$B_M = 2 Q_P \eta_{u,M} A_M$$

And the burner operation hours will be modified as

$$BOH_H = (X_H)(HLH) [(C)(A_H)(DHR) - B_H], \quad (3-10)$$

$$BOH_R = (X_R)(HLH) [(C)(A_R)(DHR) - B_R], \quad (3-11)$$

$$BOH_M = (X_H)(HLH) [(C)(A_M)(DHR) - B_M] \quad (3-12)$$

The annual fuel energy consumption will be modified as,

For two-stage modulating appliance,

$$E_F = (BOH_H)(Q_{IN,H}) + (BOH_R)(Q_{IN,R}) + [8760 - (BOH_H + BOH_R)] Q_P \quad (3-13)$$

For step-modulating appliance,

$$E_F = (BOH_M)(Q_{IN,M}) + (BOH_R)(Q_{IN,R}) + [8760 - (BOH_M + BOH_R)] Q_P \quad (3-14)$$

It is assumed that the value of Q_P is the same for all modes of operations. The general equation forms of the parameters A and B and the BOH are shown in section 3.2 previously.

Note that the above formulation is for furnaceboiler installed indoors. For furnaceboiler installed in an unconditioned space as an isolated combustion installation or installed outdoors, the current DOE test procedure ^[1] specified the procedure for modifying the calculation of the burner operating hours. The modification involved the accounting of the portions of the electric energy input to the blower motors that contribute to the heating of the conditioned space and the portions that are considered as lost to the ambient.

4. CALCULATION OF OFF-PERIOD LOSSES FOR OIL-FIRED BOILERS WITH LONG POST PURGE TIME

4.1 Background

As discussed previously, the post purge period in the test and calculation procedures of ASHRAE 103-1993 was limited to three minutes after the burner is shut off. This limit was considered adequate for most fossil-fueled appliances. However, for certain oil-fired boilers the operating requirement is such that the post purge period runs longer than three minutes. Since the longer post purge period resulted in greater off-period losses, it was deemed appropriate that calculation for the longer post purge period should be specified to account for the greater losses.

4.2 Calculation Procedure for Losses during Post Purge Period

4.2.1 Assumptions

The following assumptions were made during the derivation of the post purge period losses in ASHRAE 103-1993. They are used in the present derivation also.

- (a) Constant volumetric flue gas flow rate during post purge to equal to the on-cycle rate.
- (b) Flue gas temperature approximated by piecewise linear variation over small time interval Δt .
- (c) Measurement data of the flue gas temperature in the off-period, $T_{F,OFF}(t)$ at time interval Δt following burner shut-off.

4.2.2 Calculation for Sensible Loss

- (a) Assuming constant combustion blower or draft inducer volumetric flow rate during the post purge period to equal the steady state on-period rate results in:

$$V_{F,ON} = M_{F,ON} / \rho_{F,SS} = M_{F,OFF} / \rho_{F,OFF} = V_{F,OFF} \quad (4-1)$$

where $V_{F,ON}$ and $M_{F,ON}$ are the volumetric and mass flow rate of the flue gas during the on-period, respectively. $V_{F,OFF}$ is the off-period volumetric flow rate during post purge, and $\rho_{F,SS}$ and $\rho_{F,OFF}$ are the density of flue gas at temperatures $T_{F,SS}$ (steady state) and $T_{F,OFF}(t)$, respectively. $M_{F,OFF}(t)$ and $T_{F,OFF}(t)$ are the flue gas mass flow rate and temperature at time t during the post purge period, respectively.

From the above equation, and assuming the flue gas as a perfect gas,

$$M_{F,OFF}(t) = \frac{M_{F,ON} \rho_{F,OFF}}{\rho_{F,SS}} = \frac{M_{F,ON} (T_{F,SS} + 460)}{(T_{F,OFF} + 460)} \quad (4-2)$$

- (b) Assuming piecewise linear flue gas temperature variation over time interval Δt , ($t_i \leq t < t_{i+1}$), during the post-purge period, gives

$$T_{F,OFF}(t) = (T_{F,OFF,i} t_{i+1} - T_{F,OFF,i+1} t_i) \left(\frac{1}{\Delta t} \right) - (T_{F,OFF,i} - T_{F,OFF,i+1}) \left(\frac{1}{\Delta t} \right) (t)$$

where $T_{F,OFF,i} = T_{F,OFF}(t_i) =$ flue gas temperature at time t_i in post purge period.

Applying the factor $C_{T,OFF}$ for cycling effect to $(T_{F,OFF}(t) - T_{RA})$ as in ASHRAE 103-1993:

$$T_{F,OFF}(t) - T_{RA} = C_{T,OFF} \left\{ \left[(T_{F,OFF,i} t_{i+1} - T_{F,OFF,i+1} t_i) \left(\frac{1}{\Delta t} \right) - T_{RA} \right] - (T_{F,OFF,i} - T_{F,OFF,i+1}) \left(\frac{1}{\Delta t} \right) (t) \right\}$$

$$T_{i, OFF}(t) = T_{RA} + C_{T, OFF} \left\{ \left[(T_{F, OFF, i, i+1} - T_{F, OFF, i+1, i})(\frac{1}{\Delta t}) - T_{RA} \right] - (T_{F, OFF, i} - T_{F, OFF, i+1})(\frac{1}{\Delta t})(t) \right\} \quad (4-3)$$

where $C_{T, OFF}$ = the cool-down temperature profile correction factor for the effect of cycling^[1,2]
 T_{RA} = laboratory room air temperature.

The total sensible heat loss during the post-purge period is,

$$\begin{aligned} L_{S, purge} &= C_p \int_0^{t_p} M_{F, OFF} [T_{F, OFF}(t) - T_{RA}] dt \\ &= C_p M_{F, ON} (T_{F, SS} + 460) \int_0^{t_p} \frac{T_{F, OFF}(t) - T_{RA}}{T_{F, OFF}(t) + 460} dt \quad (\text{from equation (4-2) for } M_{F, OFF}) \\ &= C_p M_{F, ON} (T_{F, SS} + 460) \sum_{i=1}^N \left[\int_{t_i}^{t_{i+1}} \frac{T_{F, OFF}(t) - T_{RA}}{T_{F, OFF}(t) + 460} dt \right] \end{aligned} \quad (4-4)$$

where t_p = total length of post purge time interval.
 N = $t_p / \Delta t$ = number of intervals of length Δt within t_p
 C_p = specific heat capacity of flue gas

The percent sensible loss (as percent of total input during the on-cycle) during the post purge period is, by substituting the expressions for $(T_{F, OFF}(t) - T_{RA})$ and $T_{F, OFF}(t)$ above into $L_{S, purge}$, and integrate:

$$\begin{aligned} L_{S, OFF, purge} &= 100 \frac{L_{S, purge}}{(Q_{IN}) t_{ON}} \\ &= 100 \frac{C_p M_{F, ON} (T_{F, SS} + 460) \Delta t \sum_{i=1}^N \left\{ 1 - \frac{T_{RA} + 460}{C_{TS} (T_{F, OFF, i} - T_{F, OFF, i+1})} \ell n \left[\frac{T_{RA} + 460 + C_{TS} (T_{F, OFF, i} - T_{RA})}{T_{RA} + 460 + C_{TS} (T_{F, OFF, i+1} - T_{RA})} \right] \right\}}{(Q_{IN}) t_{ON}} \end{aligned} \quad (4-5)$$

where $C_{TS} = C_{T, OFF}$ for indoor combustion air,
 $= C_s' C_{T, OFF}$ for outdoor combustion air,
 C_s' = off-period correction factor for outdoor unit as defined in ASHRAE 103-1993,
 t_{ON} = burner on-time per cycle,
 Q_{IN} = fuel input rate.
100 = conversion factor from decimal to percent

4.2.3 Calculation for Infiltration Loss

The total infiltration hear loss, $L_{i, purge}$, during post purge period is, by the same way,

$$\begin{aligned}
L_{I, \text{purge}} &= C_p \int_0^{t_p} M_{F, \text{OFF}} [T_{\text{REF}} - T_{\text{OA}}] dt \\
&= C_p M_{F, \text{ON}} (T_{F, \text{SS}} + 460) (T_{\text{REF}} - T_{\text{OA}}) \sum_{i=1}^N \left[\int_{t_i}^{t_{i+1}} \frac{1}{T_{F, \text{OFF}}(t) + 460} dt \right] \quad (4-6)
\end{aligned}$$

where T_{REF} = a reference temperature defined to be 70 °F in ASHRAE 103-1993,
 T_{OA} = heating season average outdoor temperature as defined in ASHRAE 103-1993.

The percent infiltration loss (as percent of total input during the on-cycle) during the post purge period is, by substituting the expression for $T_{F, \text{OFF}}(t)$ in equation (4-3) into $L_{I, \text{purge}}$, and integrate:

$$\begin{aligned}
L_{I, \text{OFF, purge}} &= 100 \frac{L_{I, \text{purge}}}{(Q_{\text{IN}}) t_{\text{ON}}} \\
&= 100 \frac{C_p M_{F, \text{ON}} (T_{F, \text{SS}} + 460) \Delta t}{(Q_{\text{IN}}) t_{\text{ON}}} \sum_{i=1}^N \left\{ \frac{T_{\text{REF}} - T_{\text{OA}}}{C_{T, \text{OFF}} (T_{F, \text{OFF}, i} - T_{F, \text{OFF}, i+1})} \ln \left[\frac{T_{\text{RA}} + 460 + C_{T, \text{OFF}} (T_{F, \text{OFF}, i} - T_{\text{RA}})}{T_{\text{RA}} + 460 + C_{T, \text{OFF}} (T_{F, \text{OFF}, i+1} - T_{\text{RA}})} \right] \right\} \quad (4-7)
\end{aligned}$$

It is noted that when $N = 1$; $\Delta t = t_p$, and the expressions for the sensible and infiltration losses during post purge reduce to the ones in ASHRAE 103-1993.

5. BACKGROUND OF THE INTEGRAL FUNCTIONS FOR CALCULATING THE OFF-PERIOD LOSSES IN ASHRAE STANDARD 103-1993

5.1 Background

In ASHRAE 103-1993, the off-cycle sensible and infiltration losses (see sections 11.2.10.6 and 11.2.10.8 of the Standard) are calculated through the pair of functions (F3, F4); (F5, F6); or (F7, F8) depending on furnace/boiler location (indoor, outdoor, or isolated combustion system) and stack damper installation (with or without). The functions are presented in graphical forms (Figures 13 through 19 of the Standard) for manual calculation with an electronic calculator as well as in formula forms (in terms of definite integrals) presented in Appendix E of the standard. In the formulas for the functions F4, F6 and F8, there is a number 100 appearing as a divisor as well as an addition in the numerator and denominator of the first integral of each function (see Appendix E of ASHRAE 103-1993 for the exact locations). The same 100 also appears in the formula for the stack damper effectiveness factor D_0 and in the defining equations for the terms G3 and G4 in the formula for D_0 (see section 11.2.9.18 of ASHRAE 103-1993). In ASHRAE 103-1993 the term 100 was not defined. This brief report shows the origin of the term and the derivations of the integral functions.

5.2 Derivation of the Integral Functions

For illustration purpose, the following derivations use the case of a furnaceboiler using indoor air for combustion and installed indoors without a stack damper. The applicable function pair is F3 and F4.

$$L_{S,OFF} = \frac{(100)(0.24)(D_F)[1 + (R_{T,F})(A/F)](T_{F,SS} - T_{RA} + 530)^{1.19}}{(HHV_A)(t_{ON})} \int_0^{t_{OFF}} \frac{(T_{F,OFF} - T_{RA})^{1.56}}{(T_{F,OFF} - T_{RA} + 530)^{1.19}} dt$$

$$= \frac{K_{S,OFF}}{t_{ON}} \int_0^{t_{OFF}} \frac{(T_{F,OFF} - T_{RA})^{1.56}}{(T_{F,OFF} - T_{RA} + 530)^{1.19}} dt \quad (5-1)$$

In Appendix A of the report NBSIR 78-1543^[3], the off-cycle sensible heat loss is given as:

where

$$\psi_{F,0} = \psi_{F,0,X} C_{1,OFF} = C_{1,OFF} [T_{F,OFF}(t_3) - T_{F,OFF}(\infty)] e^{t_3/\tau_{OFF}}$$

$$\psi_{F,\infty} = T_{F,OFF}(\infty) - T_{RA}, \quad (t = \infty \text{ denotes reaching equilibrium condition during off-period})$$

$$T_{F,OFF}(t) = \psi_{F,0} e^{-t/\tau_{OFF}} + \psi_{F,\infty} + T_{RA}$$

t_3 = a specific time in the off-period at which the flue gas temperature is measured,
 τ_{OFF} = off-period time constant of the unit.

With the above defining equations for $\psi_{F,0}$ and $\psi_{F,\infty}$, $L_{S,OFF}$ can be written as,

$$L_{S,OFF} = \frac{K_{S,OFF}}{t_{ON}} \int_0^{t_{OFF}} \frac{(\psi_{F,0} e^{-t/\tau_{OFF}} + \psi_{F,\infty})^{1.56}}{(\psi_{F,0} e^{-t/\tau_{OFF}} + \psi_{F,\infty} + 530)^{1.19}} dt = \frac{K_{S,OFF}}{t_{ON}} \int_0^{t_{OFF}} F(t, \psi_{F,0}, \psi_{F,\infty}) dt \quad (5-2)$$

It is seen that in the above expression for $L_{S,OFF}$ is a function of t with the $\psi_{F,0}$ and $\psi_{F,\infty}$ as parameters whose values are determined from test data for a particular furnaceboiler. During the 1970s when the furnace test procedure was developed, the accurate numerical evaluation of the integral in the above expression was a major problem without using a central computer. Therefore, it was decided that graphs would be developed to facilitate the calculation with the use of an electronic calculator. However, since both $\psi_{F,0}$ and $\psi_{F,\infty}$ are related to a specific furnaceboiler and will have different values for different furnaceboiler, and a three-dimensional graph with both as parameters on a graph was not practical, a large number of graphs would be required. That is, a number of graphs with $\psi_{F,0}$ as the parametric variable, similar to the two graphs for the functions F3 and F4 in ASHRAE 103-1993, would be needed for each value of $\psi_{F,\infty}$. One way to reduce the number of graphs required was to take the parameter $\psi_{F,\infty}$ out of the integral. During the evaluation process, it was found that the function in the integral, $F(t, \psi_{F,0}, \psi_{F,\infty})$, can be approximated as a linear function of $\psi_{F,\infty}$ for constant values of t between 0 and t_{OFF} (13.3 min for furnaces and 33.3 min for boilers as assumed in the test procedure) and for constant $\psi_{F,0}$. That is, it can be assumed that

$$F(t, \psi_{F,0}, \psi_{F,\infty}) = C_1 \psi_{F,\infty} + C_2 \quad (5-3)$$

with the conditions $F = F(t, \psi_{F,0}, 0)$ for $\psi_{F,\infty} = 0$; and $F = F(t, \psi_{F,0}, 100)$ for $\psi_{F,\infty} = 100$, where the point $\psi_{F,\infty} = 100$ was arbitrarily chosen as one possible value of off-cycle flue gas temperature (differential) at equilibrium. Usually, $\psi_{F,\infty} = T_{F,OFF}(\infty) - T_{RA}$ would be much smaller than 100. Figure 5-1 shows a plot of the linear variation of the function F as a function of $\psi_{F,\infty}$ between the values of 0 to 100 for ranges of $t = 0$ min to 30 min after the burner was off for a boiler operating indoors with the value of $\psi_{F,0}$ determined by test data based on ASHRAE 103-1993. It is seen that the linear approximation is very good.




Figure 5-1 Variation of the function F versus $\psi_{F, \infty}$

With the above boundary conditions ($F = F(t, \psi_{F,0}, 0)$ for $\psi_{F,\infty} = 0$; and $F = F(t, \psi_{F,0}, 100)$ for $\psi_{F,\infty} = 100$), the functional form of C_1 and C_2 in the linear approximation can be determined as,

$$C_2 = F(t, \psi_{F,0}, 0)$$

$$C_1 = [F(t, \psi_{F,0}, 100) - F(t, \psi_{F,0}, 0)] / 100$$

Or, explicitly,

$$C_2(t, \psi_{F,0}) = F(t, \psi_{F,0}, 0) = \frac{(\psi_{F,0} e^{-t/\tau_{OFF}})^{1.56}}{(\psi_{F,0} e^{-t/\tau_{OFF}} + 530)^{1.19}}$$

$$C_1(t, \psi_{F,0}) = \frac{1}{100} [F(t, \psi_{F,0}, 100) - F(t, \psi_{F,0}, 0)]$$

$$= \left(\frac{1}{100} \right) \left[\frac{(\psi_{F,0} e^{-t/\tau_{OFF}} + 100)^{1.56}}{(\psi_{F,0} e^{-t/\tau_{OFF}} + 630)^{1.19}} - \frac{(\psi_{F,0} e^{-t/\tau_{OFF}})^{1.56}}{(\psi_{F,0} e^{-t/\tau_{OFF}} + 530)^{1.19}} \right]$$

Substituting the expressions of C_1 and C_2 into the function F inside the integral for the loss $L_{S,OFF}$ and changing the variable of integration from t to t/τ_{OFF} , result in the expression for the approximation of $L_{S,OFF}$ by the functions $F3$ and $F4$ as shown in section 11.2.10.6 of ASHRAE 103-1993.

$$L_{S,OFF} = \frac{K_{S,OFF}}{t_{ON}} \int_0^{t_{OFF}} F(t, \psi_{F,0}, \psi_{F,\infty}) dt = \frac{K_{S,OFF}}{t_{ON}} \int_0^{t_{OFF}} [C_2(t, \psi_{F,0}) + \psi_{F,\infty} C_1(t, \psi_{F,0})] dt$$

$$= (K_{S,OFF})(t_{OFF} / t_{ON}) [(F3) + (\psi_{F,\infty})(F4)] \quad (5-4)$$

where

$$F3(\psi_{F,0}, t_{OFF} / \tau_{OFF}) = \frac{1}{t_{OFF} / \tau_{OFF}} \int_0^{t_{OFF} / \tau_{OFF}} \frac{(\psi_{F,0} e^{-t/\tau_{OFF}})^{1.56}}{(\psi_{F,0} e^{-t/\tau_{OFF}} + 530)^{1.19}} d(t/\tau_{OFF}) \quad (5-5)$$

$$F4(\psi_{F,0}, t_{OFF} / \tau_{OFF}) = \frac{1}{100(t_{OFF} / \tau_{OFF})} \int_0^{t_{OFF} / \tau_{OFF}} \left[\frac{(\psi_{F,0} e^{-t/\tau_{OFF}} + 100)^{1.56}}{(\psi_{F,0} e^{-t/\tau_{OFF}} + 630)^{1.19}} - \frac{(\psi_{F,0} e^{-t/\tau_{OFF}})^{1.56}}{(\psi_{F,0} e^{-t/\tau_{OFF}} + 530)^{1.19}} \right] d(t/\tau_{OFF}). \quad (5-6)$$

It is noted that since the parameter $\psi_{F,\infty}$ is a constant, it is taken out of the integral involving $F4$ in the expression for $L_{S,OFF}$.

The function $F5$, $F6$, $F7$, and $F8$ in ASHRAE 103-1993 were derived the same way. It is noted here that in ASHRAE 103-1993, the derivation of the damper effectiveness factor D_O and the defining equations for the terms $G3$ and $G4$ in the formula for D_O (see section 11.2.9.18 of ASHRAE 103-1993) used the same approximation for the off-cycle losses (and the same term '100'). Details of that derivation is presented in the ASHRAE Transaction paper titled "The Effect of a Time Delayed Stack Damper on Off-Cycle Heat Losses for Residential Heating Equipment" by C. Park, et al.^[6]

As mentioned before, the value 100 (as one possible temperature difference between the flue gas temperature and room temperature at equilibrium during cool down) was selected arbitrarily to determine the slope of the straight line in the linear approximation of the function $F(t, \psi_{F,0}, \psi_{F,\infty})$. For furnaces the actual temperature difference would be fairly small for unit with pilot light (and

0 for unit with interrupted electronic ignition as specified in the test procedure), and for boilers the actual temperature difference would be generally much less than 100.

6. SUMMARY

This report documented the developments of proposed revisions to the ASHRAE standard 103-1993 on the method of testing for residential central furnaces and boilers. The changes include the following:

(1) A revised procedure to calculate the average burner on/off times of modulating furnaces and boilers during the cyclic operation of the burner. The procedure used the same cycles per hour at half load as were assumed for a single stage unit (5 cycles per hour for furnaces and 2 cycles per hour for boilers), thus gives a more consistent comparison with a single stage unit.

(2) A revised method for the calculation of the annual burner operating hours using the measured electric power input at the actual fuel input rate to determine the annual burner operating hours and the annual fuel and electric energy consumption at the actual burner firing rates of a modulating unit.

(3) An extension of the current procedure to calculate the off-period flue loss of oil-fired equipment with a longer post purge time. The procedure will more accurately determine the off-period flue loss that is higher when the boiler is operating with a longer than 3 min of post purge time.

This report also provides the background information on the derivation of the integral functions listed in Appendix E of ASHRAE standard 103-1993 that were not being formally documented. Those integral functions were used for producing the graphs in the standard for the hand calculation of the off-period losses with a calculator, and also in the numerical algorithm in the computerized calculation procedure.

REFERENCES

1. Code of Federal Regulations, 10CFR ~~part~~ 430, Subpart B, Appendix N, "Uniform Test Method for Measuring the Energy Consumption of Furnaces (May 1997)", January 1,2002
2. ANSYASHRAE standard 103-1993, "Methods of Testing for Annual Fuel Utilization Efficiency of Residential Central Furnaces and Boilers", ASHRAE, Atlanta, GA
3. Kelly, G.E., Chi, J., Kuklewicz, M.E., "Recommended Testing and Calculation Procedures for Determining the Seasonal Performance of Residential Central Furnaces and Boilers", NBSIR 78-1543, March 1978.
4. Chi. J.. Kelly, G.E., "A Method for Estimating the Seasonal Performance of Residential Gas and Oil-Fired Heating Systems", ASHRAE Transactions, Vol. 84, Part 1, 1978
5. Kweiler, E., "An Analysis of Burner On and Off Periods and Their Effect on Part-Load Efficiency for Furnaces and Boilers Equipped with modulating Controls", Letter Report prepared for the Department of Energy, January 1983
6. Park, C., Didion, D.A., Kelly, G.E., "The Effect of a Time Delayed Stack Damper on Off-Cycle Heat Losses for Residential Heating Equipment", ASHRAE Transactions, Vol. 89, 1983